





Test Report issued under the responsibility of:



| <b>TEST REPORT<br/>IEC 60947-2<br/>Low-voltage switchgear and controlgear - Part 2: Circuit-breakers</b>   |  |
|--|--|
| <b>Report Number</b> ..... :   | (2018)FQIIDQ-0602  |
| <b>Date of issue</b> .....   | 2019-01-23   |
| <b>Total number of pages</b> .....   | 32   |
| <b>Name of Testing Laboratory preparing the Report</b> .....   | Fujian Inspection and Research Institute of Product Quality (FQII)   |
| <b>Applicant's name</b> .....  | Zhejiang Tengen Electrics Co.,Ltd.   |
| <b>Address</b> ..... :   | Sulv Industry Zone, Liushi Town, Yueqing City, Zhejiang Province, P.R.China                                      |
| <b>Test specification:</b>   |  |
| <b>Standard</b> .....  | IEC 60947-2:2016   |
| <b>Test procedure</b> ..... :  | CB Scheme  |
| <b>Non-standard test method</b> ..... :  | N/A  |
| <b>Test Report Form No.</b> ..... :  | IEC60947_2H  |
| <b>Test Report Form(s) Originator</b> .... :   | DEKRA Certification B.V.   |
| <b>Master TRF</b> .....  | Dated 2017-04  |
| <b>Copyright © 2017 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</b>   |  |
| This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. |  |
| If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.   |  |
| <b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>   |  |
| <b>General disclaimer:</b>   |  |
| The test results presented in this report relate only to the object tested.<br>This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.                      |  |
| <b>Test item description</b> ..... :   | CBR  |
| <b>Trade Mark</b> ..... :  |  |
| <b>Manufacturer</b> .....  | Zhejiang Tengen Electrics Co.,Ltd. / Sulv Industry Zone, Liushi Town, Yueqing City, Zhejiang Province, P.R.China |



|                                   |  |
|-----------------------------------|--|
| <b>Model/Type reference .....</b> | TGM3L-250L, TGM3L-250M, TGM3L-250H   |
| <b>Ratings .....</b>              | <p>U<sub>imp</sub>:8kV;U<sub>i</sub>:800V;U<sub>e</sub>:AC400V;<br/> I<sub>n</sub>:100A,125A,140A,160A,180A,200A,225A,250A;<br/> Type of over-current release: Thermo-magnetic, electro-magnetic;<br/> TGM3L-250L:I<sub>cs</sub>:26kA,I<sub>cu</sub>:35kA;<br/> TGM3L-250M: I<sub>cs</sub>:50kA,I<sub>cu</sub>:50kA;<br/> TGM3L-250H:I<sub>cs</sub>:50kA, I<sub>cu</sub>:65kA;<br/> I<sub>Δn</sub>: 30mA(without time-delayed type)/<br/> 50mA/75mA/100mA/150mA/200mA/ 300mA/400mA/ 500mA (Optional<br/> three by fixed steps or one fixed) Type AC;<br/> t<sub>≤</sub>0.2s(without time-delayed type),<br/> Δt:0.1s/ 0.2s/0.3s/0.4s/ 0.5s/0.6s/ 0.7s/0.8s<br/> (Time-delayed type)(Optional three by fixed steps or one fixed);<br/> Type of residual current release:Electronic; I<sub>Δm</sub>:25%I<sub>cu</sub>;<br/> Selectivity:A; 3P,3P+N(Type A,3 protected poles with an<br/> uninterrupted neutral pole;Type D,3 protected poles with a<br/> protected uninterrupted neutral pole),4P(Type B,3 protected poles<br/> with a switched neutral pole;Type C,4 protected poles);<br/> 3P,4P:Suitable for isolation;<br/> 3P+N:Not suitable for isolation;<br/> Matching auxiliary contact FC34-250:<br/> 1NO1NC,2NO2NC,4NO4NC;I<sub>th</sub>:3A; U<sub>i</sub>:690V; AC-15:<br/> (380/400)V/0.3A,DC-13:(220/230)V/0.15A;<br/> Electronic accessory complying with annex N:<br/> Undervoltage release:QT34-250, U<sub>s</sub>:AC(220/230)V,AC(380/400)V;<br/> Motor-operator: CD2-250, U<sub>s</sub>:AC(220/230)V,AC(380/400)V</p> |

|   |   |
|---|---|
| <b>Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):</b> |   |
| <input checked="" type="checkbox"/> <b>CB Testing Laboratory:</b>                                 | Fujian Inspection and Research Institute for Product Quality(Fujian)  |
| <b>Testing location/ address .....</b>  | No. 121, Shan Tou Jiao West Yang Qiao Road, Fuzhou, Fujian, China   |
| <b>Tested by (name, function, signature).....:</b>  | Yang Jilin<br>(Engineer)             |
| <b>Approved by (name, function, signature) ..:</b>  | Wei Yunming (1)<br>(Chief Engineer)  |
| <input type="checkbox"/> <b>Testing procedure: CTF Stage 1:</b>                                   |   |
| <b>Testing location/ address .....</b>  |   |
| <b>Tested by (name, function, signature):</b>   |   |
| <b>Approved by (name, function, signature) ..:</b>  |   |
| <input type="checkbox"/> <b>Testing procedure: CTF Stage 2:</b>                                   |   |
| <b>Testing location/ address .....</b>  |   |
| <b>Tested by (name + signature).....:</b>   |   |
| <b>Witnessed by (name, function, signature) .:</b>  |   |
| <b>Approved by (name, function, signature) ..:</b>  |   |
| <input type="checkbox"/> <b>Testing procedure: CTF Stage 3:</b>                                   |   |
| <input type="checkbox"/> <b>Testing procedure: CTF Stage 4:</b>                                   |   |
| <b>Testing location/ address .....</b>  |   |
| <b>Tested by (name, function, signature):</b>   |   |
| <b>Witnessed by (name, function, signature) .:</b>  |   |
| <b>Approved by (name, function, signature) ..:</b>  |   |
| <b>Supervised by (name, function, signature) :</b>  |   |