

IEC**IECEE**

®

TM

Ref. Certif. No.

CN66395

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Yueqing Economic Development Branch of Zhejiang Tengen
Electric Co.,Ltd.*Note: When more than one factory, please report on page 2*No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TGM3-125C,TGM3-125E,TGM3-125N,TGM3-125L,TGM3-1
25S,TGM3-125M,TGM3-125H,TGM3-125R;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th
Edition);IEC 60947-1:2007;IEC
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

(2024)FQIIDQ-1122

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jul.04,2024

Signature:

谢肇旭

Xie ZhaoXu



TGM3-125C,TGM3-125E,TGM3-125N,TGM3-125L,TGM3-125S,TGM3-125M,
TGM3-125H,TGM3-125R;
Ui:1000V;Uimp:8kV;
Ue:AC380V/AC400V/AC415V;50Hz/60Hz;
In: 16A,20A,25A,32A,40A,50A,63A,80A,100A,125A;
Type of over-current release:Thermo-magnetic;
Type C:Ics:36kA,Icu:36kA;
Type E:Ics:40kA,Icu:40kA;
Type N:Ics:40kA,Icu:50kA;
Type L:Ics:50kA,Icu:50kA;
Type S:Ics:50kA,Icu:70kA;
Type M:Ics:70kA,Icu:70kA;
Type H:Ics:70kA,Icu:100kA;
Type R:Ics:100kA,Icu:100kA;
Trip class com.cqc.cms.component.word.CertiAnnexDataModel:16A,20A,25A,32A:10;
40A,50A,63A,80A,100A,125A:20;
Selectivity category:A; 3P,4P,3P+N;
Suitable for isolation(Except 3P+N);
Matching auxiliary contact:OF3M12,Alarm contact:SD3M12:1NO1NC,2NO2NC;
Ui:690V;lth:5A;AC-15:AC380V/400V/415V/0.3A;DC-13:DC110V/220V/250V/0.15A.

Page 1 of 1

Additional information (if necessary)

Date:

Jul.04,2024

Signature:



Xie ZhaoXu