



Ref. Certif. No.

HU-003799-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit Breaker for Overcurrent Protection
Name and address of the applicant	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Name and address of the manufacturer	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Name and address of the factory	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Ratings and principal characteristics	Ue: AC 220V/380V, 230V/400V, 240V/415V (1P); AC 220V/230V/240V (1P+N, 2P); AC 380V/400V/415V (2P, 3P, 3P+N, 4P); In: 1A, 2A, 3A, 4A, 5A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Ics=Icn: 4500A for 1), 6000A for 2); Type B, C, D
Trademark (if any)	Tengen (Logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1) TGB1N-63A , TGBG-63A 2) TGB1N-63 , TGBG-63
Additional information (if necessary may also be reported on page 2)	This Certificate is Modification No.1 to CBTC ref.No.HU-003799,dated 2022-03-04, and is issued due to additional model.
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN2100SH 002

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2024-08-29

Signature: Wencai Zhang